

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

Group Number Assessment

(In accordance with AS 5637.1-2015

This is to confirm that the product as described below has been tested by AWTA Product Testing.

Testing was performed in accordance with AS/NZS 3837-1998 Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter.

Test Sponsor: The Laminex Group

22 Trewin Street Wendouree VIC 3355 Test Number : 21-001340 Issue Date : 16/04/2021

Print Date : 23/04/2021

Sponsor Product Clients Ref : "Sample 27505 Fusion Composite Solid Surfaces"

Rigid panel
Colour: Grey

End Use: Wallcovering

Nominal Composition: Melamine resin impregnated paper Nominal Mass per Unit Area/Density: Approx 19.1kg/m2

Nominal Thickness: 13mm

Product Group Number Classification : 3

Average Specific Extinction Area: 4.3 m²/kg

Firms McDanald

Fiona McDonald Testing Technologist

50479

The message/document(s) contained in this electronic attachment is intended for the party to which it is addressed and may contain confidential information or be subject to professional privilege. It's transmission is not intended to place the contents into the public domain.